

Park Forest Cooperative IV Area E
Electrical Requirements

- **No Romex.**
- **No BX to be used.**
- **Where hard pipe conduit cannot be used, Greensfield is to be used (keeping length as short as possible).**
- **If fixture specified is conduit, then conduit is to be used.**
- **If requirements are not met, work will not be approved by the Cooperative Maintenance Department.**
- **Any hole made to install electrical work will be the contractor's responsibility to restore to the original condition.**

Please call the Cooperative Management Office at (708) 748-9005 if you have any questions.